

**विनिर्माण गुणवत्ता योजना अनुमोदन / MQP APPROVAL**
**संदर्भ: CC/QA&I/2025/E-1098482/Letter/558**
**दिनांक: 03.NOV-2025**

<b>निर्माता का नाम/ Name of Manufacturer</b>	M/s Cell Com Teleservices Pvt. Ltd		
<b>सी.आई.एन सं./ CIN Number</b>	U64201UP2002PTC153593		
<b>निर्माता का पता/ Address of Manufacturer</b>	A-52, A35, A36 UPSIDC Industrial Area, Sikandrabad, Distt Bulandshahar		
	<b>City:</b> Bulandshahar	<b>State/Country:</b> Uttar Pradesh / India	<b>Pin/Zip Code:</b> 203205
<b>निर्माता कोड/ Manufacturer Code</b>	3000001995		
<b>नाम और संपर्क विवरण/ Name &amp; Contact details</b>	Sh. Pradeep Kumar Sharma +91-9910897849 pradeep.sharma@cellcom.in		
<b>मद का नाम &amp; गुणवत्ता योजना सं./ Item Name &amp; MQP no.</b>	Transmission line Tower/ Parts up to 400 kV MQP no: C/QA&I/MQP/Standard/ Tower Parts Rev 06 and Substation Structure (Lattice and Pipe) upto 400 kV MQP No: CC/QA&I/SMQP/Lattice & Pipe Structure/Rev 00		
<b>निर्माता अनुमोदन का संदर्भ/ Manufacturer approval letter ref. No. &amp; date</b>	CC: ENGG-TL: ASSESMENT: CELL COM dated 29.10.2025		
<b>संचार संदर्भ/ Communication reference</b>	Email dated 30.10.2025		
<b>वैधता अवधि/ Validity period up to</b>	<b>28-Oct-2026</b> (One year from date of approval letter of CC-Engg- TL)		
<p>This MQP shall be read in conjunction with the contract specific technical specification / approved drawing/ data Sheets/ GTP/ test procedures, relevant IS standards and project specific type tests. Manufacturer shall ensure that the above documents are available at the works so that proper inspection is carried out without delay. Please note that further approval shall be considered based upon performance, quality and supplies during this approval period. Manufacturers shall ensure that request for renewal of above approval should come at least one month before expiry of this approval.</p> <p>While on the subject, we wish to clarify that process inspection/ audit for above item(s) shall continue to be carried out by POWERGRID in adherence to this MQP at your works. In case of serious and repeated observations of process/process parameter violation and if any problem is encountered with regards to the quality, we reserve the right to increase our involvement by way of additional quantum of inspection and / or additional Customer Inspection Points (CIP) at any stage or withdraw this MQP.</p>			
<b>Special Remarks:</b>			
<ol style="list-style-type: none"> <li>For TLT- During this approval period, Sampling plan for final testing shall be 01 sample for every 50 MT/ section /lot or part thereof for each source (reroller/ manufacturer) as per Sl. No. 3, clause c under column 'Quantum of Check/Sampling with basis' of the MQP</li> <li>In case of saving in samples during final testing, due to call combination necessary recovery shall be carried out.</li> <li>Recovery shall be carried out on account of reduction in samples for destructive testing and saving on account of reduction in testing of samples at Third party lab.</li> <li>Recovery on account of call combination shall not be applicable in case clause no 8.24 of Quality Assurance Programme regarding call combination, is part of TS/ LOA and accordingly clause no ' 2 &amp; 3 ' above shall not be applicable.</li> </ol>			
<b>Important Note:</b>			
<ol style="list-style-type: none"> <li>For supplying Grade-C material for POWERGRID projects, the impact testing shall be carried out at third party accredited laboratory till inhouse facility is established by M/s Cell Com.</li> <li>Welder qualification to be carried out as per the POWERGRID guidelines prior to executing any order for substation structure involving welding activity ( copy attached).</li> </ol>			

**Note 1:** "The ministry of MSME has launched the "Financial Support to MSMEs in ZED certification scheme" for benefit of MSMEs. MSMEs are requested to avail maximum benefits under the scheme. For more details on ZED, you may please visit this link- (<https://zed.org.in/>)."

**Note 2:** Manufacturing Quality Plan attached.

**Note 3:** Letter regarding- Non-Indulgence in Fraudulent / Unethical Practices is attached.

**अनुराग अरोड़ा**  
 वरिष्ठ उप महाप्रबंधक (गु° आ° एवं नि°)

**प्रति: सम्बंधित निरीक्षण कार्यालय**

**Enclosure: As above**